

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 7120-0476:126 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Harrington Signal Inc., 2519 4<sup>th</sup> Avenue, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

DESIGN: Model HS-2802 and HS-3140 Remote Annunciators. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

HS-2802	Basic Board
HS-2802E	Enhanced Board
MR-2622/-2902	Annunciator Strip
MR-2915	LED Driver
MR-2944/-2944LC/-2944LCD	Driver Board
MR-2910-X	Communication Board

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as remote annunciators for use with separately listed compatible Model HS-3400 (CSFM Listing No. 7165-0476:114) and HS-3030 (CSFM Listing No. 7165-0476:110) fire alarm control units.

XLF: 7120-1429:103

10-15-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager